


VERIFICATION OF COMPLIANCE

No.: LVD GZES1609013763HS
Applicant: Laswim Pool and Spa Equipment Co., Ltd.
16 Jianye Road, Nantou Town, Zhongshan, Guangdong, China
Manufacturer: Same as applicant
Product Description: **Pumps**
Model No.: WL-A1SB, WL-AHP, WL-BHP, WL-HLLF, WL-ESP, WL-HEP,
WL-SCPB, WL-STP, WL-SKPB, WL-XFP, WL-CEP
Trade Mark: 
Rating: 220 V- 240 V; 50 Hz – 60 Hz; 2,2 KW; 10 A
Protection against Electric Shock: Class I
Degree of Protection: IPX5
Additional Information: —
Sufficient samples of the product have been tested and found to be in conformity with
Test Standard: EN 60335-2-41: 2003 + A1: 2004 + A2: 2010
EN 60335-1: 2012 + A11: 2014
EN 62233: 2008
as shown in the
Test Report Number(s): GZES160901376301

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant harmonized standards under the Low Voltage Directive 2014/35/EU. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.


David Guo
Senior Technical Manager
SGS-CSTC



2017-05-26

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)